



2023 Drinking Water Quality Report

City of Ocala Water Resources
1805 NE 30th Ave., Bldg. 600
Ocala, FL 34470

Public Water System Identification #342-0922

Table of Contents

Introduction	1
Types of Contaminants	2
Glossary	3
Water Quality Test Results	4
Lead and Copper (Tap Water)	4
Inorganic Contaminants	5
Stage 2 Disinfectants and Disinfection By-Products	6
Radioactive Contaminants	6
Unregulated Contaminants	7

Contact Information

City of Ocala Water Resources Department
1805 NE 30th Ave. Bldg. 600
Ocala, FL 34470

Phone: 352-351-6772
Website: www.ocalafl.gov
Email: water@ocalafl.gov

Public Water System
Identification #342-0922

Citizens' Service Center
201 SE 3rd St.
Ocala, FL 34471

Phone: (352) 629-2489
Email: OEU@ocalafl.gov

Photos by:
Maven Photo + Film
Dave Miller for Ocala Style
Gabriela Sullivan

Follow us on social media!

  Ocala Wetland
Recharge Park



Quality Water to Every Tap

City of Ocala Water Resources is pleased to provide this year's Drinking Water Quality Report. We would like to keep you informed about the excellent water and services delivered over the past year. Our goal is, and always has been, to provide a safe and dependable supply of drinking water.

Our water is obtained from ground water from six source wells which draw from the Upper Floridan Aquifer. The water is softened and chlorinated for disinfecting purposes and fluoridated for dental health purposes. This report shows our water quality results and what they mean.

Ocala's water treatment facilities have won numerous awards for operations, distribution and maintenance excellence. In 2023, the City of Ocala was awarded best-tasting drinking water at the Region XI North Central Florida Best Tasting Drinking Water competition presented by the Florida Section of the American Water Works Association.

In 2023, the Florida Department of Environmental Protection (FDEP) performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are 57 unique potential sources of contamination identified for this system with low to high concern levels. The assessment results are available on the FDEP Source Water Assessment & Protection Program (SWAPP) website at:



Types of Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations or wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- (E) Radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline: 1-800-426-4791.

Maximum Contaminant Levels (MCL) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink two liters of water every day for a lifetime at the MCL to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA or Center for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline: 1-800-426-4791.



Glossary

For clarity regarding terms and abbreviations in the accompanying tables, please see the following definitions:

Action Level (AL):

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Initial Distribution System Evaluation (IDSE):

An important part of the Stage 2 Disinfection By-Products Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with the highest concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.

Maximum Contaminant Level Goal (MCLG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL):

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level (MRDL):

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG):

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Not Detected (ND):

Indicates that the substance was not found by laboratory analysis.

Parts per million (ppm) or Milligrams per liter (mg/L):

One part by weight of analyte to one million parts by weight of water sample.

Parts per billion (ppb) or Micrograms per liter (µg/L):

One part by weight of analyte to one billion parts by weight of water sample.

Parts per trillion (ppt) or nanograms per liter (ng/l):

One part by weight of analyte to one trillion parts by weight of the water sample.

Picocurie per Liter (pCi/L):

Measure of the radioactivity in water.

Treatment Technique (TT):

A required process intended to reduce the level of a contaminant in drinking water.



2023 Water Quality Test Results

The City of Ocala routinely monitors for contaminants in your drinking water according to federal and state laws, rules, and regulations. Except where indicated otherwise, this report is based on the results for the period January 1, 2023 through December 31, 2023. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. Data obtained before January 1, 2023, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.



Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of Sampling (Mo./Yr.)	AL Exceeded Y/N	90th Percentile Result	No. of Sampling Sites Exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (Tap water) (ppm)	06/23	N	0.012	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (Tap Water) (ppb)	06/23	N	0.7	0	0	15	Corrosion of household plumbing systems

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead/>.

2023 Water Quality Test Results

In continuing efforts to maintain a safe and dependable water supply, it may be necessary to make improvements to the water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

Please DO NOT FLUSH your unused or unwanted medications down toilets or sink drains. More information is available at: <http://www.dep.state.fl.us/waste/categories/medications/pages/disposal.htm>

Inorganic Contaminants							
Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling (Mo./Yr.)	MCL or MRDL Violation Y/N	Highest Result	Range of Results	MCLG	MCL	Likely Source of Contamination
Arsenic (ppb)	04/23	N	0.73	ND-0.73	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronic production waste
Fluoride (ppm)	01/23-12/23	N	0.75	0.17-0.75	4	4.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories; water additive which promotes strong teeth
Barium (ppm)	04/23	N	0.0056	0.0046-0.0056	2	2	Erosion of natural deposits; discharge of drilling wastes; discharge from metal refineries
Nitrate (as Nitrogen) (ppm)	03/23	N	1.7	1.4-1.7	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	04/23	N	10.2	7.3-10.2	N/A	160	Salt water intrusion, leaching from soil

2023 Water Quality Test Results

We at the City of Ocala would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Water conservation tips are available at www.ocalaf1.gov under Government/City Departments I-Z/Water Resources. If you have any questions or concerns about the information provided, please feel free to call our office directly at 352-351-6772.

Stage 2 Disinfectants and Disinfection By-Products

Disinfectant or Contaminant and Unit of Measurement	Dates of Sampling (Mo./Yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	01/23-12/23	N	1.09	0.50-1.24	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
TTHM [Total Trihalomethanes] (ppb)	05/23-08/23	N	18.05	14.3-21.8	N/A	MCL = 80	By-product of drinking water disinfection
Haloacetic acids (five) (HAA5) (ppb)	05/23-08/23	N	2.45	2.0-2.9	N/A	MCL = 60	By-product of drinking water disinfection

For chlorine, the level detected is the highest Running Annual Average (RAA), computed quarterly, of monthly averages of all samples collected. The level detected for HAA5 or TTHM is the level detected is the Locational Running Annual Average (LRAA) of samples taken on May 9, 2023 and August 8, 2023. Range of Results is the range of individual samples collected during the past year.

Radioactive Contaminants

Radioactive Contaminant and Unit of Measurement	Dates of Sampling (Mo./Yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Uranium (µg/L)	04/23	N	1.01	ND-1.01	0	30	Erosion of natural deposits

2023 Water Quality Test Results

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by the EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. City of Ocala utility customers have a right to know that this data is available. If you are interested in examining the results, please contact us at 352-351-6772.



Unregulated Contaminants				
Contaminant and Unit of Measurement	Dates of Sampling (Mo./Yr.)	Level Detected	Range	Likely Source of Contamination
Perfluorobutanesulfonic acid (PFBS) (ng/L)	08/22	6.3	6.3	Manmade chemical; used in products to make them stain, grease, heat and water resistant
Perfluorohexanoic acid (PFHxA) (ng/L)	08/22	13	13	Manmade chemical; used in products to make them stain, grease, heat and water resistant
Perfluoroheptanoic acid (PFHpA) (ng/L)	08/22	9.0	9.0	Manmade chemical; used in products to make them stain, grease, heat and water resistant
Perfluorohexanesulfonic acid (PFHxS) (ng/L)	08/22	49	49	Manmade chemical; used in products to make them stain, grease, heat and water resistant
Perfluorooctanesulfonic acid (PFOS) (ng/L)	08/22	45	45	Surfactant or emulsifier; used in fire-fighting foam, circuit board etching acids, floor polish, and as a pesticide
Perfluorooctanoic acid (PFOA) (ng/L)	08/22	6.3	6.3	Used for its emulsifier and surfactant properties in or as fluoropolymers (such as Teflon), fire-fighting foams, cleaners, cosmetics, grease and lubricants, paints, polishes, adhesives and photographic films

We voluntarily monitor for Per and Polyfluoroalkyl substances (PFAS) annually and have included the results above. The EPA proposed an MCL of 4 ng/L for PFOS and PFOA. Results in the Level Detected column are the highest detected level at the point of entry.




Saving **Water** Just Got Easier

City of Ocala utility customers can access their water usage from a computer or smartphone using the EyeOnWater® App.



Scan QR Code to
Download & Sign Up



The EyeOnWater® App allows users to:



Receive potential leak notifications



Compare water usage by week, month and even year



Use savings calculator to estimate monetary savings



Discover and monitor usage trends

How to Sign Up

1. Visit eyeonwater.com/signup or download the EyeOnWater® App from the Apple App Store or Google Play.
2. Enter your account number, including the hyphen, found on your utility bill.
3. Enter your billing ZIP code.
4. Click next.
5. Enter your email address.
6. Create and confirm a password.
7. Check your inbox and verify your email address by clicking the confirmation link from Badger Meter Inc.
8. Sign in and let the water savings begin!